



1 ROOF POWER PLAN  
E1.2

SCALE: 1/8" = 1'-0"

**GENERAL NOTES**

- SEE SHEET E1.1 FOR MAIN POWER PLAN.
- SEE SHEET E6.1 FOR PANELBOARD SCHEDULES.
- SEE LIGHTING ON SHEET E1.3 FOR EXHAUST FAN IN BATHROOM CIRCUIT INFORMATION.
- ELECTRICAL CONTRACTOR TO WORK WITH MECHANICAL CONTRACTOR IN REGARDS OF THE DISCONNECT SWITCH BEING PROVIDED WITH THE RTU OR IF THE ELECTRICAL CONTRACTOR TO PROVIDE.

**ROOF POWER PLAN NOTES**

- MOUNT SERVICE RECEPTACLE WITHIN 25 FOOT OF ANY ROOF TOP UNIT.

REVISION	DATE

I hereby certify that this plan, specification or report was prepared by me or under my direct supervision and that I am a duly Licensed Engineer under the laws of the state of Minnesota.

*R. Scott Jones*  
R. Scott Jones, P.E.  
Date: 02/09/2007 License No. 25389

**ROOF POWER PLAN**

PROJECT NO.:	06752
SCALE:	AS NOTED
DATE:	02/09/2007
DRAWN BY:	ALR
CHECKED BY:	RSJ

**DESIGN DEVELOPMENT**

**E1.2**